

**RE: Georgetown-Scott County EMS  
690 Lexus Way  
Georgetown, KY 40324  
Project No. 21143**

**FROM: Brandstetter Carroll Inc.  
2360 Chauvin Dr.  
Lexington, KY 40517  
Phone 859-268-1933**

**TO: Plan Holders**

This addendum forms a part of the Construction Documents and modifies the original bidding documents dated July 13, 2023. Each bidder shall acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of one (1) page, and attachment.

**GENERAL ITEMS AND CLARIFICATIONS:**

1. This will be the final addendum for the project.
2. Clarification to Note #8 on S-100 Foundation Plan – note applies to all interior masonry walls.

**SUBSTITUTION REQUEST APPROVALS:**

*All substitutions are still bound by criteria set forth within specification and the drawings. No deviations from requirements will be accepted because of product substitution. Contractor is responsible for burden of proof of compliance with specification.*

1. Scranton Products is an approved manufacturer of Toilet Partitions per Specification Section 102113 Toilet Compartment.

**CHANGES TO DRAWINGS:**

**1. C-102 Site Plan – Layout & Materials**

- A. The heavy duty concrete hatch on the legend has been revised to reflect what is shown on the drawings.

**2. S-303 Sections & Details**

- A. E2/S-303 – Delete note regarding foundation bearing on rock or lean concrete. Delete Lean concrete from detail drawing.
- B. E3/S-303 – Delete detail in it's entirety.

**3. A-001 Wall Types**

- A. At Partition Types E2 and E4: Revise CMU note to read: "12" CMU, REINFORCED PER STRUCTURAL"


**CHANGES TO SPECIFICATIONS:**

**1. 001113 Advertisement for Bids**


- A. §1.5-A: Contract Time to be revised to 300 calendar days.

**END OF ADDENDUM NO. 1**

# Legend




CONCRETE WALK/PAD – SEE E2/C-501



ASPHALT PAVEMENT – SEE C1/C-501


2



HEAVY DUTY CONCRETE/APRON – SEE E1/C-501



HEAVY DUTY PAVEMENT – SEE E1 & C2/C-501



EXPANSION JOINT.



REVERSE CURB & GUTTER – SEE C6/C-501

