

**ADDENDUM NO. 2**

**August 02, 2023**

**RE: Georgetown-Scott County EMS  
690 Lexus Way  
Georgetown, KY 40324  
Project No. 21143**

**FROM: Brandstetter Carroll Inc.  
2360 Chauvin Dr.  
Lexington, KY 40517  
Phone 859-268-1933**

**TO: Plan Holders**

---

This addendum forms a part of the Construction Documents and modifies the original bidding documents dated July 13, 2023. Each bidder shall acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of three (1) page, and no attachments.

**GENERAL ITEMS AND CLARIFICATIONS:**

1. Due to a plan room/plan distribution error, the bid opening date is to be postponed by one week. Bids will be received on August 10, 2023, at 2:00pm local time. The location remains unchanged.

**CHANGES TO DRAWINGS**

1. All G-, A-, and I- sheets currently issued with the date: "May 18, 2023" are correct, however the issue date is to be revised to July 13, 2023.
2. Sheet S-100
  - A. The wall reinforcement for the perimeter storm shelter masonry walls shall be labeled as Type "3" and will be fully grouted.

**CHANGES TO SPECIFICATIONS:**

1. **236500 Fluid Cooler**
  - A. Delete reference in part 3.3.A Coil Assembly requiring compliance with ASME B31.5.

**END OF ADDENDUM NO. 2**