



**ADDENDUM NO. 2**

**May 12, 2022**

**RE:                Beaumont Public Library  
3080 Fieldstone Way  
Lexington, Kentucky 40513  
Project No. 21134**

**FROM:           Brandstetter Carroll Inc.  
2360 Chauvin Drive  
Lexington, Kentucky 40517  
Phone 859-268-1933  
Fax 859-268-3341**

**TO:               Plan Holders**

---

This Addendum forms a part of the Construction Documents dated April 26, 2023. Each Bidder shall acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of one page.

**CHANGES TO SPECIFICATIONS:**

All substitutions are still bound by criteria set forth within the Specification and the drawings. No deviations from requirements will be accepted because of product substitution. The Contractor is responsible for burden of proof of compliance with the Specification.

1. 086223 – Tubular Skylights
  - a. Refer to 2.2B
    - i. Reference to 330DS-o shall be changed to DS-C.
  - b. Curbs shall be integral to the unit and flashed in accordance with the manufacturer's written instructions.
2. 104000 – Miscellaneous Building Specialties
  - a. Soundcore Folded Baffles may be considered an acceptable manufacturer.

**END OF ADDENDUM NO. 2**