



ADDENDUM NO. 2

April 22, 2024

**RE: Washington County Emergency Services
65 Honeysuckle Way
Springfield, Kentucky 40069
Project No. 22047**

**FROM: Brandstetter Carroll Inc.
2360 Chauvin Drive
Lexington, Kentucky 40517
Phone 859-268-1933
Fax 859-268-3341**

TO: Plan Holders

This Addendum forms a part of the Construction Documents and Specifications dated April 3, 2024. Each Bidder shall acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of one (1) page and no attachments.

CHANGES TO DRAWINGS:

1. S-101 Foundation and Shelter Roof Framing Plan
 - a. The foundations shall be installed at the elevations shown on S-101. If construction phasing/sequencing will allow for the grade to be raised prior to the installation of the modular retaining wall system, the foundation elevations may be adjusted to closer match what is shown on A-201 of the architectural drawings. However, the foundation elevations shown in the structural drawings were to allow the foundations to be installed prior to the modular retaining wall system.

END OF ADDENDUM NO. 2