

**ADDENDUM NO. 3**

**September 16, 2022**

**RE: Nolanville Community Center – Phase 1 Addition + Renovation  
Nolanville, Texas  
BCI Project No. 21104**

**FROM: Brandstetter Carroll Inc.  
17300 Preston Road Suite 310  
Dallas, Texas 75252  
Phone: 469-941-4926**

**TO: Plan Holders**

---

This addendum forms a part of the Construction Documents and modifies the original bidding documents dated **August 17, 2022**. Each bidder shall acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of **one (1)** pages, no attachments.

**Changes to drawings:**

**1. A-101 & A-201:**

- A. Add Alternate #5: Rainwater harvesting tanks: Disregard the note pertaining to underground pumps. The system shall be gravity flow with hose bibb usage.

**END OF ADDENDUM NO. 3**